

TAMIL NADU FIRE AND RESCUE SERVICES

NO OBJECTION CERTIFICATE

R.C.No: 216/V/PDI/2026

Date: 19.08.2026

Subject : Tamilnadu Fire and Rescue services Department - Fire and Rescue service

Station - purpose of No Objection Certificate – Reg.,

Ref: (1) G.O.No.122. School Edu (2) Dept, Date: 14.09.2004

(2) G.O.No.123. School Edu (2) Dept, Date: 14.09.2004

(3) Date of Requisition letter from THE CORRESPONDENT, SAIRAM

VIDYALAYA, Date: 18.08.2026

Based on the Government order mentioned above and the Requisition letter given by the **SAIRAM VIDYALAYA** at Sai Leo Nagar, Poonthandalam Village, Chennai – 600 044 . Tamil Nadu the building and premises comprises **SAIRAM VIDYALAYA** running in a G+2 floor only have complied with the fire prevention and fire safety requirements in accordance with rule of state fire service rules, and verified on 18.08.2026 in the presence of Principal and that the school is granted NOC for a period of 1 year from 19.08.2026 to 18.08.2027 subject to the conditions stated below

This certificate does not valid for swimming pool in that premises area.

The above premises inspected by station officer, Fire and Rescue Service Station, Padappai, Mr.K.GNANAVEL on 18.08.2026

CONDITIONS

1. This License Valid for ONE YEAR from the data of issue.
2. Fire safety system should be maintained in good working condition.
3. Mock Drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A Trained Fire Service Person, preferably retired on should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are instead.
 - a). Building occupancy /capacity should not be more than 4 people per sq.mtr as per the National building code - 2005
 - b) The Staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.

- c) As per para 6.3 of the BIS standards is 14435:1997 as the classrooms have only one entrance, the capacity of the classrooms shall have to be limited to 45 students.
- d) Periodical Maintenance and care should be taken to maintain all fire protection equipments.
- e) Mock Drill has to be conducted at Regular intervals in consultation with District fire Officer, Fire and Rescue Service, Kanchipuram District.
- f) The classroom should always be in the Ground floor up to 3rd standards.
- g) The classroom doors/windows should be made of either non Combustible material or materials with high fire resistance rating.
- h) The classroom doors/windows shall always open outwards.
- i) The classroom doors/windows shutters when opened should not obstruct movement along the exit or escape route.
- j) A classroom shall have to entrances. one door with opening towards the teachers and the other door on the other end of the classroom with only a simple latch/tower bolt arrangement for locking from inside.
- k) This door Shall not have any arrangement for locking from outside.
- l) The school shall have proper Evacuation of plan action to rescue the children during any emergency in the school premises.
- m) Hose Reel System & Fire Alarm System Should be provided within 3 month.

If there any violation and deviation from the Govt. rule and Act, the License it should will stand cancelled.



K. E. S.
STATION OFFICER,
FIRE AND RESCUE SERVICES,
PADAPPAI,
KANCHIPURAM DISTRICT.

To:

THE CORRESPONDENT,
SAI RAM VIDYALAYA
SAI LEO NAGAR,
POONTHANDALAM, CHENNAI – 600 044.

Copy to: Distict Officer, Kanchipuram District.

S. J. D.
PRINCIPAL
SAIRAM VIDYALAYA
WEST TAMBARAM
CHENNAI - 600 044.

For SAIRAM VIDYALAYA
S. J. D.
CHAIRMAN